

Inoperable Summary 9/2/2017 PM	
Drinking Water	37
Wastewater	38
Total	75

Inoperable Public Drinking Water Systems 9/2/2017

County	PWSID	PWS Name	Population	Connections	Issue/ Start Date	BWN/Shutdown Reason
Harris	1012806	ALTON THEISS SUBDIVISION		45	9/2/2017	WTP not operational, significant damage.
Harris	1010085	APACHELAND MOBILE HOME SUBDIVISION		177	8/31/2017	#16 Follow up in 3-5 days #17 Entire system under potentially 4 feet of water. There isn't access to the system.
Victoria	2350042	ARENOSA CREEK ESTATES		65	9/1/2017	residents evacuated and are returning; however, no power or water is available.
Liberty	1460025	BIG THICKET LAKE ESTATES 1		76	8/29/2017	
Aransas	40058	CAPTAIN KENS RV PARK		30	8/31/2017	#3 No power. Has only seen well site from a distance. Well house is gone. He plans to go out today, 8/31/17, and evaluate the status. #5 Looking for a smaller more portable generator to use. Plans to use it intermittently due to fuel concerns. #10 System is completely down.
Jefferson	1230020	CARDINAL MEADS IMPROVEMENT		154	9/1/2017	
Orange	1810190	CHURCH OF JESUS CHRIST OF LDS VIDOR		681	9/1/2017	BWN will be posted at the church until negative TC/BacT samples come back.

					8/31/2017	One GW Plant is down, it is underwater = snyder plant (TP1133)+ well (g0200001 B) Won't be able to assess damage until utility water recedes Contact info for Brandon Moody, mobile 832 -398-0180 Backup contact: Brian Smith, Director of Public Services, 713-859-0482
Brazoria	200001	CITY OF ALVIN		24000		
					9/1/2017	2. Area under mandatory evacuation per system contact. Contact unable to get in to area to view extent of damage. 3. Area under mandatory evacuation per system contact. Contact unable to get int o area to view extent of damage. 7.Area under mandatory evacuation per system contact. Contact unable to get int o area to view extent of dama 11. Unable to montior quality of water. 12. No where to post notice, system under mandatory evacuation. Boil Water Notice materials sent to TCEQ BWN Dept.
Jefferson	1230049	CITY OF BEVIL OAKS		1274		
Victoria	2350002	CITY OF VICTORIA		67444	8/27/2017	
					9/2/2017	facility experiencing intermittent water. contingent on City of Rockport for water supply.
Aransas	40003	COPANO COVE SUBDIVISION		1446		

Harris	1011651	CYPRESS FIELDS SUBDIVISION		441	8/31/2017	11. OPERATOR UNABLE TO ACCESS SITE DUE TO FLOODING. 12. BWN method of issuance not specified.
Harris	1010254	CYPRESS PLACE		147	8/31/2017	11. OPERATOR UNABLE TO ACCESS SITE DUE TO FLOODING. 12. BWN method of issuance not specified.
Montgomery	1700040	ENCHANTED FOREST		54	8/28/2017	11. Precautionary BWN issued. 12, BWN method of issuance not specified.
Brazoria	200218	HASTINGS HOMEOWNERS WATER SYSTEM		177	8/29/2017	BWN was issued due to power loss
Liberty	1460085	HUNTSMAN PETROCHEMICAL DAYTON FACILITY		50	8/31/2017	#2 Voluntarily shut down power to facility, no known damage. #4 Waiting on a generator to be delivered. #5 Once the generator is in use, has more than a weeks worth of fuel available on site. #7 The goal is to be, at least partially, operational tomorrow. Trying to have enough water for safety showers and sprinkler system, but not for drinking. #11 Power outage.
Liberty	1460164	INDIAN SPRINGS WATER SYSTEM		183	8/28/2017	Outage List

					9/2/2017	2, Unknown extent of damage at this time due to system experiencing flooding. 3. Unknown extent of damage at this time due to system experiencing flooding. 10. Intends to issue a boil water notice once able. 15. Customers are providing themselves with water. Contact is a volunteer operator for this system and needs technical assistance or financial assistance for getting the system back up and running. Contact tates it could be days or weeks until an assessment on system is possible.
Harris	1011567	KINGSLAND ESTATES WSC		36		
					8/29/2017	John Sexton self-reported an outage for the PWS on 8/28/2017 in the SB/LGA Outage website. Q.3. Fallen trees tore out water lines. Q.7. Expect to have service restored on 8/30/2017. Q.16. Follow up on or after 8/31/2017 to check status.
Liberty	1460007	LAKE LIVINGSTON BIG THICKET LAKE 2		435		
					8/28/2017	11. Precautionary BWN issued. 8/30 BWN Mandatory 12, BWN method of issuance not specified.
Harris	1011510	MARKS GLEN SUBDIVISION		258		
Matagorda	1610052	MATAGORDA DUNES SUBDIVISION		426	8/30/2017	Outage List

Montgomery	1700773	MONTGOMERY COUNTY MUD 119 SPRING TRAILS		3126	8/29/2017	BWN issued due to well failure
Harris	1010915	NORTH WOODS ESTATES		102	8/31/2017	11. OPERATOR UNABLE TO ACCESS SITE DUE TO FLOODING. 12. BWN method of issuance not specified.
Jefferson	1230086	NORTHWEST FOREST MUD		615	9/1/2017	Purchase water system, from Beaumont. No power, no service, zero pressure. There is still flooding, but the water is receding. Customers are still evacuated.
Brazoria	200617	PALM CREST		117	8/29/2017	BWN was issued due to power loss
Waller	2370005	PATTISON WSC		1461	8/29/2017	Ms Chapa said the system is flooded and can not completely assess the level of damage. Will need follow up in one week to further assess the system's needs.
Calhoun	290028	PORT ALTO WSC		115	9/1/2017	
Harris	1010307	REDWOOD ESTATES MOBILE HOME PARK		510	8/28/2017	11. Precautionary BWN issued. 8/30 BWN Mandatory 12. BWN method of issuance not specified. 8/30/2017 - No Power Water and Wastwater
Montgomery	1700778	RIO VISTA SUBDIVISION		117	8/29/2017	Q.3. Well pump inoperative. Q.7. Will try to access and repair well on 8/30/2017. Access limited by flood waters. Q.16. Follow up on or after 9/1/2017 to check status.

					8/30/2017	Generators used only to power a few offices. Facility is off-line and the main potable water line was damaged so no potable water can be distributed. The facility was informed that they needed to issue a boil water notice (BWN) prior to providing water to the facility. Once the distribution system has been adequately flushed and both pressure and disinfectant residual restored, bacteriological samples will need to be collected and once negative then BWN can be rescinded.
Calhoun	290054	SEADRIFT COKE PLANT		180		
Harris	1010320	SHELL OIL DEER PARK		2585	8/29/2017	
Brazoria	200053	SNUG HARBOR SUBDIVISION		99	8/31/2017	
Aransas	40055	SUNSET BAY		0	9/1/2017	Power is expected to be restored by Setpember 8th. Nobody is living there now

					9/1/2017	2Q - TCDJ has evacuated these units associated with this PWS. System has been shut down since August 29. As of 9/1, they are waiting for water to recede to determine any damage before we turn system back on. 8-13Q - The TDCJ Ramsey Area serves 3 units and units ave been evacuated, they will have to check wells and water plant systems for any damage before they can make determination to turn system back on
Brazoria	200201	TDCJ RAMSEY AREA		5119		
					9/1/2017	The facility does not have power. The system only serves 11 customers. The customers are not residing in the area due to damage to trailers.
Victoria	2350009	THE ESTATES OF SANDY HILLS		18		
					8/31/2017	Finishing electrical checkout. Generators are available but awaiting grid power which is expected to be restored by tomorrow (1/1/17). Once power is restored, water distribution will begin under BWN for toilets. Then system will be pressured up to flush and then BACT samples will be collected.
Calhoun	290003	UNION CARBIDE SEADRIFT PLANT		683		

Brazoria	200019	WEYBRIDGE SUBDIVISION WATER SYSTEM		87	8/31/2017	
----------	--------	---------------------------------------	--	----	-----------	--

Inoperable Wastewater Systems 9/2/2017

Status	ID	WW Name	Issue	County	Contact Name	Contact #
Destroyed	12936001	BOLIVAR UTILITY SERVICES LLC - CRYSTAL PALACE WWTP	Crystal Palace completely destroyed, no access	Galveston	Chris Makin	409-684-9941
Destroyed	10008002	CITY OF CONROE - SOUTHWEST REGIONAL WWTP	2. 9 ft of water in the facility. 5. Facility is completely flooded. POC thinks all equipment is destroyed. Greg Hall Jr. can be reached at cell at (936) 521-5114	Montgomery	Greg Hall Jr.	936-521-5114
Inoperable	14218001	ARCHDIOCESE OF GALVESTON HOUSTON - CIRCLE LAKE RETREAT CENTER WWTP	4. No power 10. no power, not currently collecting 13. On generator within one day hopefully Phone number 281-356-6764 not functional possibly due to storm.	Montgomery	Gloria Bustillo	281-900-7244
Inoperable	13563001	BEACH ROAD MUD - BEACH ROAD MUD WWTP	Tornado hit, the clarifier was hit by debris, draining system and trucking wastewater to Bay City, WWTP. The collection system is a vacuum system, the was damage, They are working on fixing the system	Matagorda	Emil Krejci	979-429-7081
Inoperable	10124004	CANEY CREEK MUD - CANEY CREEK MUD OF MATAGORDA COUNTY	PWRT referral Facility was hit by a tornado. Debris landed on treatment units and caused damage to the plant and generator.	Matagorda	Donald Fox	979-429-1027
Inoperable	11713001	CEDAR BAYOU PARK UTILITY DISTRICT - CEDAR BAYOU PARK WWTP	both lift station and facility are both currently under water and cannot be reached. permittee is concerned that the facility may not be operational when the water recedes	Harris	Jerald Landin	713-818-3602
Inoperable	13172002	CINCO MUD 1 - CINCO RANCH SOUTH WWTP	Waiting on a status update on WWTP. Alot of information was unknown.	Fort Bend	James Wolfe	281-740-6540

Inoperable	14581001	CITY OF BRAZORIA - CITY OF BRAZORIA WWTP	The whole treatment system is being bypassed because it is completely under water. The lift station to the plant is above water and accessible by boat, but the river has not crested.	Brazoria	David Jordan	979-798-2489
Inoperable	10008002	CITY OF CONROE - SOUTHWEST REGIONAL WWTP	plant located 5 miles from lake conroe record release from lake facility completely under water	Montgomery		936-521-5114
Inoperable	10495146	CITY OF HOUSTON - KINGWOOD CENTRAL WWTP	Q5. No power at plant, lift stations have no power. Transformers, elec. panels, and switch gear needs repair. The plant has major electrical issues. Plant has a bypass pump on the way to set up at the lift station. Generator and bypass pumps not working. Q9. Bypass pumps and generators were flooded and are not operable. Q10. No SSO occurring. Area was evacuated so there are not a lot of people in area flushing toilets etc. at this point. Q11. Don't know extent or time but manholes were underwater.	Harris	Johnathan Dawson	281-830-4015
Inoperable	10108001	CITY OF LIBERTY - CITY OF LIBERTY MAIN WWTP	#4 under 10 ft of water Really unable to perform an assessment due to the majority of plant being under 10 ft of water	Liberty	Mark Reed	936-661-3424
Inoperable	15294001	CITY OF PATTON VILLAGE - PATTON VILLAGE WWTP	9. All 5 lift stations flooded and submerged (now 3/5)	Montgomery	Ryan Bobo	832-318-5348
Inoperable	15294001	CITY OF PEARLAND - BARRY ROSE WWTP	#5 System is under water washed out, generator working Referred to TX WARN	Brazoria	Laurie Rodriguez	281-652-1900
Inoperable	10134010	CITY OF PEARLAND - LONGWOOD WWTF	Referred to TX WARN	Brazoria	Laurie Rodriguez	281-652-1900

Inoperable	10134002	CITY OF WEST COLUMBIA - CITY OF WEST COLUMBIA WWTP	WWTP has been shut down. Entire collections system including lift stations are under water. WWTP is no longer accessible.	Brazoria	Terry Elliot	979-481-3027
Inoperable	14404001	CORIX UTILITIES TEXAS INC - MATAGORDA BAY NATURE PARK AND PRESERVE WWTP	-no structural damage, just power outage - Power expected to be and fully operational as soon as tomorrow, 8/31/2017	Matagorda	Gloria Broussard	512-306-4001
Inoperable	14823001	FARMERS TRANSPORT INC - SUNILANDING WWTP	Jesse Wood is expecting power to be restored within the hour. Generator is available; however, Mr. Wood reported that it would be faster for the electricial company, which is right down the street to restore power than powering up the generator. Otherwise, doesn't see any problems at the site.	Calhoun	Jesse Wood	979-637-0010
Inoperable	11844001	FOREST GLEN INC - FOREST GLEN WWTF	WWTP was shut off before it flooded. A digester is damaged and has leaks. Three tanks leaked out during the storm event. Currently everything is being contained and no spills are occuring. Lost approximately 18000 gallons of activated sludge (Mostly liquids and approximately 20-30% solids). Facility is still currently assessing damage. Collection system fluid was pumped out by trucks.	Walker	Justin Perrit	936-295-7641
Inoperable	13245001	GRAND LAKES MUD 4 - GRAND LAKES REGIONAL WWTP	System is innaccessible. System is underwater.	Fort Bend	Susan Young	281-258-1212

Inoperable	11061001	GREENWOOD UTILITY DISTRICT - GREENWOOD UTILITY DISTRICT WWTP	Flooded generator has to be dried out before use. 2 offsite lifts are operable. The subscriber district parkway has seven lift stations that we do not have complete status updates on. Collection status NOCNSSO. Overflows system is underwater.	Harris	Susan Young	281-258-1212
Inoperable	10528001	HARRIS COUNTY FWSD 52 - HARRIS COUNTY FWSD 52 WWTF	3. Water is 7 feet deep, flooded generator. Power to meter only. Fuses being replaced today 5. Chlorine contact basin needs repair/replacement. Aeration basins and clarifier OK. 6. WWTP should be fully operational by Saturday or Sunday 7. WWTP not operational yet due to power issues. Disinfection was affected. 9. dry well underwater. Should be fixed today or tomorrow. 11. Initiated "No flush" to district since Saturday. 13. One to two days	Harris	Phillip Dautrich	832-473-6578
Inoperable	11523001	HARRIS COUNTY MUD 102 - HARRIS COUNTY MUD 102 WWTP	Disinfection. Collection is partial. Parts are underwater.	Harris	Susan Young	281-258-1212
Inoperable	10104001	HARRIS COUNTY WCID 1 - HARRIS COUNTY WCID 1 WWTP	2. Unknown - facility is still partially flooded 5. Power + Units to feed the chlorine + SO2 compromised/Cannot Access basins until flood waters recede further 8. Clear Lake lift station needs new motors, electrician is on-site now 11. Reported to Region -Overflows at lift stations + WWTP	Harris	Mark Taylor	281-426-2115
Inoperable	1218001	HORSEPEN BAYOU MUD - WILLIAM H PORTER WWTP	Yes - all four blowers continued to run pumping creek water thru the plant. Once we arrived we shut off two of the pumps. Parts of the system is underwater however all lift stations are okay,	Harris	Susan Young	281-258-1212

Inoperable	11290001	JACKRABBIT ROAD PUD - JACKRABBIT ROAD PUD WWTP	5 ft of water in facility David Walker 8322501142 has more informtion on the plant	Harris	John Montgomery	281-217-1031
Inoperable	11084001	LAKE FOREST PLANT ADVISORY COUNCIL - LAKE FOREST REGIONAL WWTP	Flooded but the plant can handle being flooded (made for it). Lift station may be down. Facility is 10 miles down creek.	Harris	Gregory Camp	281-902-0966
Inoperable	10104001	MONTGOMERY COUNTY MUD 139 - MONTGOMERY COUNTY MUD NO 139 WWTP	The WWTP is not operating. Have lost grid power from Entergy. They have called into Entergy to report outage. Disinfection is working. They have not yet checked on the generator. I asked Mr. Reno to call me back, but we should check on him in a day or two. Juan Ibarra, EPA	Montgomery	James Reno	832-381-8140
Inoperable	11386001	MONTGOMERY COUNTY MUD 16 - MONTGOMERY COUNTY MUD NO 16 WWTP	Lost power for waster treatment plant. The generator was damaged due to floods (powererd by diesel). Power has been out for 2 days. they are adding chlorine to the water to disinfect. 4 feet of water in the facility electircal is out. basins and collection is okay. Collection system has power. 90 % that they will have power returned by the end of today.	Montgomery	Stephen Woodring	281-850-7001
Inoperable	14619001	TEXAS DEPARTMENT OF TRANSPORTATION - GUADALUPE COUNTY TXDOT IH 10 REST STATIONS	The WWTP is down due to power failure. Everything should work fine once power is restored.	Guadalupe	Ned Pyatt	512-952-1840
Inoperable	11141001	TRESCHWIG JOINT POWERS BOARD - TRESCHWIG CENTRAL WWTP	Plant is offline - flooded (unknown status)	Harris	Gregory Camp	281-902-0966
Inoperable	12088001	US ARMY CORPS OF ENGINEERS - ROCKY CREEK PARK WWTP	Lift station is damaged. Park is closed so no one has been affected.	Washington	Randall McCartney	979-596-1624

Inoperable	11624001	ARANSAS COUNTY MUD 1 - ARANSAS COUNTY MUD 1 WWTP	Electrical components at both the WWTP and the lift stations have been damaged and are needing repair. Working on gathering/purchasing/borrowing additional generators for WWTP and lift stations. No SSOs have occurred. Expect the WWTP repairs and generators to be running by the end of the day. Liftstations generator status unclear.	Aransas	Jack Chaney	361-463-6121
Inoperable	14578001	BLOOMINGTON ISD - BLOOMINGTON JUNIOR HIGH AND HIGH SCHOOL WWTP	Misty Bansfield states the system has been out of power since the storm. Crews currently onsite working to restore power. Facility is waiting on inspectors for a full evaluation of the WWTP and collection system. Ms. Bansfield was given the TCEQ Region 14 office main line and asked to call if/when an update is available.	Victoria	Misty Bansfield	361-649-6871
Inoperable	10495151	CITY OF HOUSTON - WILLOW RUN WWTP	Plant decommissioned. This plant has been shut down and is not in operation.	Harris	Walid Samarneh, PE	832-395-5771
Inoperable	10626001	CITY OF ORANGE - JACKSON STREET WWTP	9- The operational status of the collection system is unknown due to an electrical issue at the plant.	Orange	Timmy Campbell	409-238-9103
Inoperable	11518001	HUFFMAN ISD - WILLIE J HARGRAVE HIGH SCHOOL WWTP		Harris	Doug Wade	832-465-8029
Inoperable	14319001	ODA, MIKE - RIVERBEND RV PARK AND RESORT WWTP	5. RV park evacuated, WWTP off for 6 days 4. RV park has been evacuated 3. and 5. Anticipate for power to be back on in net few days, waiting for flooding to subside No damage aside from flooding has been assessed 8. collection system will be assessed when plant is back on. collection system will be assessed when plant is back up	Fort Bend	Elena Oda	832-455-1612

Inoperable	13804001	TEXAS DEPARTMENT OF CRIMINAL JUSTICE - TERRELL WWTP	3. Generators are available. 4. plant is shut off due to current flooding and evacuation. 9. unknown Entire facility is shut down. Flood water has to recede before knowing status	Brazoria	Tony Robinson	936-355-2829
------------	----------	---	---	----------	---------------	--------------